FILED

DEC 16 2004

HEARING BOARD BAY AREA AIR QUALITY MANAGEMENT DISTRICT

MARY ROMAIDIS

CLERK

BEFORE THE HEARING BOARD OF THE

HEARING BOARD
BAY AREA AIR QUALITY

BAY AREA AIR QUALITY MANAGEMENT DISTRICT
STATE OF CALIFORNIA

In the Matter of the Application of)
DUBLIN SAN RAMON SERVICES DISTRICT)
For a Variance from Regulation 2, Rule 1, Section 307 (Permit Condition No. 17263, Item No. 3))

ORDER GRANTING VARIANCE

NO. 3479

The above-entitled matter is an Application for Variance from District Regulation 2-1-307 and from the provisions of operating Permit Condition No. 17263, Item No. 3 (Carbon Monoxide emission limit of 2.1 g/bhp-hr), for Source S-22, Plant A1371, located at 7399 Johnson Drive, Pleasanton, California. The Application for Variance was filed on November 12, 2004, and requested short-term relief for the period from the date of filing through and including January 12, 2005.

Rob E. Fowler, and Carl P. A. Nelson, Assistant General Counsel, appeared on behalf of Dublin San Ramon Services District (DSRSD) ("Applicant").

Alexander Crockett, Assistant Counsel, appeared for the Air Pollution Control Officer ("APCO").

The Clerk of the Hearing Board provided notice of this hearing on the Application for Variance in accordance with the requirements of the California Health and Safety Code. The Hearing Board heard the request for variance on December 2, 2004. The Application was amended at the hearing to request a variance through and including February 2, 2005.

i

The Hearing Board provided the public opportunity to testify at the hearing as required by the California Health and Safety Code, but no one did so. The Hearing Board received documentary evidence, and heard testimony and argument from the Applicant and the APCO. The APCO did not oppose the granting of this variance.

After hearing argument, the Hearing Board took the matter under submission for decision.

After consideration of the evidence, the Hearing Board voted to grant the request for variance, subject to six conditions as set forth in more detail below.

BACKGROUND

Applicant operates a publicly owned treatment work ("POTW") that treats wastewater from approximately 115,000 customers in the area of Dublin, Pleasanton, and San Ramon, in Alameda and Contra Costa Counties. The POTW separates solid material out of the incoming wastewater, and then treats the organic solids in a 2 million gallon biological solids digestion process. The treatment process is designed to meet pathogen and vector regulations, to reduce odors that could cause a nuisance, and to render the solid material suitable for disposal.

The digestion process produces digester gas, composed of approximately 60% methane and 40% CO2, as a byproduct of the organic solids digestion process. The facility uses the digester gas (blended with natural gas, as needed) to power two identical 706 hp internal combustion engines. The engines have been assigned Source Nos. S-13 and S-22 by the District. Source S-22, the second engine, is the subject of DSRSD's variance application.

DSRSD's engines serve three critical functions at the POTW. First, they generate heat to keep the solids digestion process at an optimal process temperature of 98° F. Without adequate heat, the digestion process would fail, causing a number of adverse effects, including: ineffective treatment of wastewater causing violations of water quality discharge standards; a digester gas stream of poor quality that could not be properly combusted and would have to be emitted without abatement, causing odors and potential public nuisances; and the failure of sludge lagoons downstream of the digestion process, causing further odors that could cause public nuisances up to

a mile or more away.

Second, these engines combust the digester gas so that it does not have to be abated in a flare. The facility has a flare that would have to be used to abate the digester gas if one or more of the engines became unavailable for any reason. Third, the engines generate electricity to provide power for the facility, reducing the facility's demand on the electricity grid, thereby reducing utility-produced emissions.

District regulations require that Applicant use the Best Available Control Technology ("BACT") to control CO emissions from its engines (among other pollutants). The level of emissions control required by BACT is determined at the time the District issues permits for the engines. The BACT emission limit can be established in either of two ways.

BACT can be established as the level of emissions control that has been actually achieved in practice by other similar sources. (See District Regulation 2-2-206.2.) This level of emissions control is known as "BACT 2 - Achieved in Practice", and can be thought of as the "industry standard" level of control. This is the level of control made applicable to Source S-13.

A more stringent level of control, known as "BACT 1," may be applied if it is determined to be "Technologically Feasible & Cost Effective" for a particular facility. (See District Regulation 2-2-206.3.) This level of control may or may not be appropriate depending on a detailed, facility-specific review of the feasibility and cost effectiveness on a case-by-case basis. This is the level of control made applicable to Source S-22.

DISCUSSION

Current permit conditions require Applicant to comply with a BACT 1 permit requirement that CO emissions from Source S-22 not exceed 2.1 g/bhp-hr. The November 4, 2004 source test was the first indication that Source S-22 was out of compliance with the above CO emissions limit. (Even in the failed source tests, Source S-22 has always been in compliance with the CO emission limit of 2.65 g/bhp-hr that is applicable to Source S-13.)

The other engine operated by Applicant – not the subject of the variance application

13 14

15 16

17

18

19

24

25

26

here – is Source S-13; the District adopted a BACT 2-based CO emission limit of 2.65 g/bhp-hr for that engine, based on emissions performance actually achieved in practice by other similar engines, in part because the manufacturer stated that the engine could not reliably achieve a more stringent limit. Source S-13 continues to be subject to the BACT 2-based limit under its current permit conditions.

Applicant has accordingly submitted an application for review of the current CO permit condition for Source S-22, and has submitted evidence from the manufacturer of the two engines stating that the engines cannot reliably achieve a more stringent limit of CO emissions. During the requested variance period the CO emissions will be 20.9 pounds per day of unabated emissions in excess of District Regulation limits for Source S-22. Applicant shall pay the excess emission fees for such excess emissions as required by, and in accordance with, District Regulation 3.

SPECIFIC FINDINGS

The Hearing Board finds pursuant to Health and Safety Code Section 42352 that:

- 1. Applicant will be in violation of District Regulation 2, Rule 1, Section 307 (Permit Condition No. 17263, Item No. 3) (requiring a Carbon Monoxide ("CO") emission limit of 2.1 g/bhp-hr.), for Source S-22 during the variance period.
- 2. Due to conditions beyond the reasonable control of the Applicant, requiring compliance with District Regulation 2, Rule 1, Section 307 (Permit Condition No. 17263, Item No. 3) would impose an unreasonable burden upon an essential public service and thereby result in (A) an arbitrary and unreasonable taking of property, and/or (B) the practical closing and elimination of an otherwise lawful business. Compliance during the period of the variance would require Applicant to shut down the engine. Because the digestion process cannot be adequately heated without heat from the engine, shutting down the engine would essentially disable the facility, preventing it from properly treating incoming wastewater properly, and causing a number of adverse effects, including the potential for violations of water quality discharge standards and

odor nuisances. This shutdown of the facility's ability to operate properly would constitute the effective closure of a lawful business. Furthermore, if Applicant shuts down the engine it will have to purchase electrical power purchased from the electric grid to replace the power that would have been generated by the engine, at a cost of approximately \$40,000 for 2 months of supply. Under the circumstances, such a cost would constitute an unreasonable taking of property.

After failing the November 4, 2004 source test performed by a District inspector,
Applicant hired a source test firm, Blue Sky Environmental ("Blue Sky"), to independently verify
the source test results. Despite making numerous adjustments and instituting a more rigorous
maintenance program on the engine identified as Source S-22, Applicant was unable to reduce the
CO emissions sufficiently to comply with the emission limit of 2.1 g/bhp-hr for Source S-22,
although the source test would have complied with the CO emissions limit of 2.65 g/bhp-hr
(applicable to Source S-13, an identical engine). Accordingly, non-compliance with District Rules
was beyond Applicant's reasonable control. Once Applicant discovered that Source S-22 was
exceeding the CO emissions limit, the only way it could have complied with the regulatory limit
would have been to shut down the engine.

3. The hardship due to requiring immediate compliance with District Regulation 2, Rule 1, Section 307 (Permit Condition No. 17263, Item No. 3) would be without a corresponding benefit in reducing air contaminants. Although shutting down the engine would eliminate the emissions from the engine, around 20 lbs. of excess CO per day, it would also require the methane gas that is normally burned in the engine to be sent to a flare, which could involve greater emissions than burning it in the engine. Furthermore, the extra electricity that Applicant would have to purchase would have to be generated elsewhere, increasing emissions at the alternate generation site. Finally, shutting down the engine would ultimately cause failure of the facility's treatment process, which would cause significant unabated odor emissions. (As noted above, such a failure would impose an unreasonable burden upon an essential public service.) It is, therefore, likely that denying the variance and requiring DSRSD to shut down the engine would actually cause

///

///

///

26 || /

greater emissions than granting a variance requiring DSRSD to operate the engine in compliance with a BACT 2 standard pending a permit review.

- 4. Applicant has carefully considered possibilities for curtailing operations of the source in lieu of obtaining a variance. However, for the reasons described earlier, Applicant does not believe that it would be reasonable or warranted under the circumstances, given the costs and emission consequences of doing so. Furthermore, unlike water, electrical or natural gas service, each of which can be shut off at a meter, there is no effective way to prevent inflows into a wastewater collection system without significant adverse health and safety impacts. Applicant has no direct control over those who contribute wastewater to the system, and in any event those who contribute wastewater could not completely curtail their wastewater production during the period covered by the variance application even if Applicant did have direct control over them.
- 5. Applicant has identified steps that it will take to keep CO emissions as low as possible, including those identified in its variance application (increasing gas sulfide monitoring from 2X/week to every other day, increasing tune up, oil, lube and filter frequency from 1000 hours to 500 hours, maintaining engine load to minimize emissions, and increasing monitoring of engine cylinder temperatures and adjust as needed) and will continue to identify others. During the period the variance is in effect, Applicant will undertake to reduce excess emissions by implementing the above steps.
- 6. Except for the submission of the results of the December 1, 2004 source test as required by Condition 4, District staff has not requested Applicant to monitor or otherwise further quantify any emission levels beyond what is already required by the Permit.

THEREFORE, THE HEARING BOARD ORDERS:

A variance from Regulation 2, Rule 1, Section 307 (Permit Condition No. 17263, Item No. 3) is hereby granted from November 12, 2004 to and including February 2, 2005, subject to the following conditions:

- Applicant shall continue to process its application for review of the current CO
 permit condition for Source S-22.
- Applicant shall take all feasible steps to keep CO emissions as low as possible, including those identified in its variance application (increasing gas sulfide monitoring from 2X/week to every other day, increasing tune up, oil, lube and filter frequency from 1000 hours to 500 hours, maintaining engine load to minimize emissions, and increasing monitoring of engine cylinder temperatures and adjust as needed) and any others identified by the District.
- 3) Applicant shall not operate engine S-22 with CO emissions in excess of 2.65 g/bhp-hr.
- Applicant shall, by December 15, 2004, report, in writing, to the Hearing Board and the District, the results of the source test on Source S-22 conducted by Blue Sky on December 1, 2004. The report shall be submitted to the Clerk of the Hearing Board in an original plus nine copies.
- 5) Applicant shall permanently mark the respective exterior of each of the engine panels to clearly identify which is Source S-13, and which is Source S-22.
- Applicant shall provide to the Hearing Board and the District the serial number, make, and model of the engine identified as Source S-13 and the engine identified as Source S-22.
- Applicant shall pay excess emission fees pursuant to District Regulation 3,
 Schedule A.

1	Moved by:	Allan R. Saxe, Esq.,
2	Seconded by:	Terry A. Trumbull, Esq.
3		
4		Christian Colline, P.E., Julio Magalhães, Ph.D., Allan R. Saxe, Esq., Terry A. Trumbull, Esq., Thomas M. Dailey, M.D.
5	NOES:	None.
6		
7		A
8	Mon	WM AUD 12-16-04 Date
9	Thomas M. Da	illey, M.D., Chair Date
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21	 	
22		
23		
24		
25		
26		
	11	